

Wir, die

F. W. Oventrop GmbH & Co. KG

Paul-Oventrop-Str.1
D-59939 Olsberg

erklären in alleiniger Verantwortung, dass die folgenden Produkte mit folgenden Normen und normativen Dokumenten übereinstimmen:

DIN EN 12514-2 : 2000-05

Produkt

„Oilstop V“ und „Oilstop F“ Membran-Antiheberventile

Artikelnummer	DN [mm]	Max. Betriebsdruck p _s	Betriebs- temperatur t _s	CE- Zeichen
210 42 03	10	Saugdruck *)	0°C bis +40°C	Nein
210 42 51				
210 42 52				
210 42 53				

*) max. zulässiger Prüfdruck: bis 6 bar


Die „Oilstop V“ und „Oilstop F“ Membran-Antiheberventile sind vom TÜV Rheinland nach oben genannter Norm geprüft. Entsprechend der deutschen Bauregelliste A Teil 1 Ausgabe 96/1 lfd. Nr. 14.1ff wird das Produkt mit dem Ü-Zeichen gekennzeichnet.

Überwachung QS-System:

DQS 000211 QM


Olsberg, den 11.05.2009

i. V.



Dr. Foitzik
Technischer Leiter

i. A.



Dipl.-Ing. Tigges
Projektleiter

We, **F. W. Oventrop GmbH & Co. KG**

Paul-Oventrop-Str. 1
D-59939 Olsberg

Hereby declare at sole responsibility that the following products to which this declaration refers to, correspond to the standards and technical specifications

DIN EN 12514-2 : 2000-05

Product

Diaphragm anti siphon valves "Oilstop V" and "Oilstop F"

Item no.	DN [mm]	Max. working pressure ps	Working temperature range ts	CE-marking
210 42 03	10	suction pressure *)	0°C up to +40°C	No
210 42 51				
210 42 52				
210 42 53				

*) Max. permissible test pressure: up to 6 bars.


The diaphragm anti siphon valves "Oilstop V" and "Oilstop F" are tested by TÜV Rheinland in accordance with the above mentioned standard and specification. According to the German Construction Regulation List A Part 1 Edition 96/1 ser. no. 14.1 and following the products are marked with the sign Ü (UHP-method).

Monitoring system:


DQS 000211 QM

Olsberg, 11.05.2009

i. V.


Dr. Foitzik
Technical director

i. A.


Dipl.-Ing. Tigges
Project manager