

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085BT0244Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) EG-Gasgeräte-Richtlinie (2009/142/EG)
Distributor <i>Vertreiber</i>	ROWI Schweißgeräte und Elektrowerkzeuge Vertrieb GmbH Augartenstraße 3, D-76698 Ubstadt-Weiher
Product Category <i>Produktart</i>	gas fittings: Pressure regulator for LPG (4302)
Product Description <i>Produktbezeichnung</i>	Pressure regulator for LPG optionally with safety relief valve (PRV) and manometer
Model <i>Modell</i>	HGD 1/1 D
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: 544/4914/1293 from 22.01.2015 (FGL)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 16129 (01.08.2013) DIN 4811 (01.06.2008)

File Number
Aktenzeichen 14-0860-GEA

13.03.2015 Rie B-1/2

Date Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
HGD 1/1 D	outlet pressure: 50 mbar inlet pressure range: 0,3...16 bar nominal pressure rating: PN 16 nominal flow rate: 1,5 kg/h	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
HGD 1/1 D	connection: at the input side G12, at the outlet side H4, H9, in each case according to DIN EN 16129; with thermal shut off valve; class F1-t acc. to DIN 4811

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

ambient temperature range: -20...+50 °C

trip pressure of PRV: 95 mbar (maximum 150 mbar)

In Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Macedonia.

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085BT0244Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Distributor <i>Vertreiber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Product Category <i>Produktart</i>	gas fittings: Pressure regulator for LPG (4302)
Product Description <i>Produktbezeichnung</i>	Pressure regulator for LPG optionally with safety relief valve (PRV) and manometer
Model <i>Modell</i>	424 RV; 424 DT; 424 D; 424 M
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: 544/4914/1293 from 22.01.2015 (FGL)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 16129 (01.08.2013) DIN 4811 (01.06.2008)

File Number
Aktenzeichen 14-0860-GEA

13.03.2015/Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
424 RV; 424 M	outlet pressure: 30 mbar inlet pressure range: 0,3...16 bar nominal pressure rating: PN 16 nominal flow rate: 1,5 kg/h	
424 DT; 424 D	outlet pressure: 50 mbar inlet pressure range: 0,3...16 bar nominal pressure rating: PN 16 nominal flow rate: 1,5 kg/h	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
424 RV	connection: at the input side G1, G2, G4, G5, G7, G8, G9, G10, G12, G13, G19; at the outlet side H1, H4, H7, H9, in each case according to annex D of DIN EN 16129
424 DT	connection: at the input side G12, at the outlet side H4, H9, in each case according to DIN EN 16129; with thermal shut off valve; class F1-t acc. to DIN 4811
424 D	connection: at the input side G12, at the outlet side H4, H9, in each case according to DIN EN 16129; class F1 acc. to DIN 4811
424 M	connection: at the input side G2, G12, at the outlet side H4, in each case according to annex M of DIN EN 16129

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

ambient temperature range: -20...+50 °C

trip pressure of PRV: 95 mbar (maximum 150 mbar)

In Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Macedonia.