



Application:

Refill granules for all standard neutralisation systems with condensates from condensing boilers.

Neutralising agent:

MgO granules refined with Anti-Algin

The neutralisation system must be maintained at least once a year. Only then, a proper neutralisation is guaranteed! The OEG universal granules can be used to completely replace or refill the used granules.

The following procedure is recommended for maintenance:

- Disconnect the neutralisation system from inlet and outlet ports
- Replace or refill used granules completely for universal granules
- Clean neutralisation if required
- Reconnect inlet and outlet ports of neutralisation system

Grain size	PU	Art. No.
2 – 4 mm	2,5 kg bag	510 520 074
2 – 4 mm	5,0 kg canister	510 520 076
5 – 10 mm	2,5 kg bag	510 499 953
5 – 10 mm	5,0 kg canister	510 520 072